


OFFICE OF THE CHIEF MEDICAL OFFICER PRAYAGRAJ

No .CMO/EPI/WATER & SANI/2026-27/ 6919


Date-25/9/26


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by DR. RASHID ALI from CMO OFFICE PRAYAGRAJ PHED. Inspected the. TAGORE PUBLIC SCHOOL, 179-A ATTARSUIYA PRAYAGRAJ. on. 25-09-2026. and on the basis of Valid Water Test Report for 3 month's (Attached) bearing no. DW/01/LAB 2026-09/11 dated. 18-09-2026 OF JALKAL VIBHAG NAGAR NIGAM PRAYAGRAJ PHED. Certified that the TAGORE PUBLIC SCHOOL, 179-A ATTARSUIYA PRAYAGRAJ. has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt. This Certificate is Valid Till. ONE YEAR


Chief Medical Officer
Prayagraj.

To Principal
TAGORE PUBLIC SCHOOL
179-A ATTARSUIYA
PRAYAGRAJ


Archana Tewari
Principal
Tagore Public School
Attarsuiya, Allahabad


AMIT KHANNA
(Manager)
Tagore Public School
Attarsuiya, Prayagraj



कार्यालय अधिरात्री अधिनता (मु०)
जलकल विभाग-नगर निगम प्रयागराज
मु० ज० क० न०
दिनांक 16/09/26

JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2026-09/11

Date: 18.09.2026

DRINKING WATER ANALYSIS REPORT

1	Name & Address	TAGORE PUBLIC SCHOOL-179-A, ATTARSUIYA, ALLAHABAD-211003
2	Sample Collected by	By Party
3	Nature of Sample	DRINKING WATER
4	Date of Sample Collection	16.09.2026
5	Date of Sample Receiving	16.09.2026
6	Date of Analysis Completed	18.09.2026

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	-
3.	Temperature	°C	28.2	-	-
4.	Turbidity	NTU	0.6	5	10
5.	Conductivity at 25°C	µmho/cm	240.0	-	-
CHEMICAL PARAMETERS					
6.	pH	-	6.7	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	NIL	-	-
8.	Dissolved Solids	mg/L	119.0	500	2000
9.	Total Solids	mg/L	119.0	-	-
10.	Total Alkalinity (as CaCO ₃)	mg/L	73.0	200	600
11.	Total Hardness (as CaCO ₃)	mg/L	124.0	200	600
12.	Chlorides (as Cl)	mg/L	70.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	NIL	1.0	1.5
14.	Nitrate (as NO ₃)	mg/L	NIL	45.0	100.0
15.	Iron (Fe)	mg/L	NIL	0.3	1.0
BACTERIOLOGICAL PARAMETERS					
16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

Validity- three months only

Analyst

JE(HQ)

अधिरात्री अधिनता (मु०)
जलकल विभाग
नगर निगम-प्रयागराज
E.E(HQ)

Archi Tewari
Principal

AMIT KHANNA
(Manager)
Tagore Public School
Attarsuiya, Prayagraj

Note:

- The above results are related only to the test performed on the sample.
- This report is not to be reproduced wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.
- Sample will be destroyed in the after fifteen days from the date of reporting.

